

*Ovaj prijevod sastoji se
od 11 stranica
Broj: 167/2020
Datum: 18. ožujka 2020.*

Ovjereni prijevod s engleskog jezika





Instytut Techniki Budowlanej

Istrażivački i razvojni radovi | Akreditirana grupacija laboratorija |

Prijavljeno tijelo br. 1488 | Član EOTA-e | Certificirani sustavi upravljanja ISO 9001, ISO 27001

KLASIFIKACIJA VATROOTPORNOSTI U SKLADU S EN 13501-2:2016

Klijent:	<i>SELENA FM S.A. 2-4, Strzegomska St. 53-611 Wrocław Poljska</i>	
Izradio:	<i>Odjel za istraživanje požara Institut za istraživanja u vezi s izgradnjom (Fire Research Department, Building Research Institute) 1, Filtrowa St. PL 00-611 Varšava</i>	
Naziv proizvoda:	<i>Brtnice linearnih spojeva izrađene pomoću PREMIUM B1 STRAW pjene za nanošenje slamčicom ili PREMIUM B1 GUN pjene za nanošenje pištoljem društva Orion PU Sp.z.o.o.</i>	
Klasifikacijsko izvješće br.:	06052/15/R29NP/ENG	
Br. izdanja	1	Br. primjerka: 1
Datum izdavanja	13.12.2017.	

Ovo izvješće o klasifikaciji sastoji se od 11 stranica i može se koristiti ili reproducirati samo u cijelosti.

1. UVOD

Izvešće o klasifikaciji utvrđuje klasifikaciju otpornosti na vatru pripisanu ispitnom elementu – brtve linearnih spojeva u zidu, izrađene pomoću PREMIUM B1 STRAW pjene za nanošenje slamčicom ili PREMIUM B1 GUN pjene za nanošenje pištoljem društva Orion PU Sp. z.o.o., u skladu s postupcima navedenima u normi EN 13501-2:2016.

2 DETALJI O KLASIFICIRANOM PROIZVODU

2.1. Općenito

Element – brtve linearnih spojeva u zidu, izrađene pomoću PREMIUM B1 pjene za nanošenje slamčicom ili PREMIUM B1 pjene za nanošenje pištoljem društva Orion PU Sp. z.o.o.


2.2. Opis

Element - brtve linearnih spojeva u zidu, izrađene pomoću PREMIUM B1 pjene za nanošenje slamčicom ili PREMIUM B1 pjene za nanošenje pištoljem opisane su u nastavku.


Brtve linearnih spojeva izrađene su pomoću:

- a) vatrootporne poliuretanske pjene PREMIUM B1 pjene za nanošenje slamčicom – verzija sa slamčicom – nanošenje poliuretanske pjene elastičnom slamčicom, ili
- b) vatrootporne poliuretanske pjene BREMIUM B1 GUN – verzija s pištoljem – primjena poliuretanske pjene pištoljem.

Pregledi i presjeci brtvi linearnih spojeva prikazane su na slici 1. i 2.

2.2.1. Tip 1 –brtve vertikalnih linearnih spojeva u vertikalnoj potpornoj konstrukciji

Slika 1. Pregled i presjek brtve vertikalnih linearnih spojeva u zidu

2.2.2. Tip 2 - brtve horizontalnih linearnih spojeva u vertikalnoj potpornoj konstrukciji

Slika 2.: Pregled i presjek brtve horizontalnih linearnih spojeva u zidu

3. ISPITNA IZVJEŠĆA/PROŠIRENO IZVJEŠĆE O PRIMJENI I REZULTATI ISPITIVANJA NAVEDENA U PRILOG KLASIFIKACIJI

3.1. Ispitno izvješće/proširena izvješća o primjeni

Naziv laboratorija	Naziv klijenta	Izvješće ref.br.	Ispitno izvješće
Odjel za istraživanje požara Institut za istraživanja u vezi s izgradnjom (<i>Fire Research Department, Building Research Institute</i>), 2, Przemysłowa St. 26-670 Pionki	SELENA FM S.A. 2-4, Strzegomska St. 53-611 Wrocław Poljska	LZP01- 00867/17/Z00NZP	PN-EN 1366-4 +A1:2011
Odjel za istraživanje požara Institut za istraživanja u vezi s izgradnjom (<i>Fire Research Department, Building Research Institute</i>), 2, Przemysłowa St. 26-670 Pionki	SELENA FM S.A. 2-4, Strzegomska St. 53-611 Wrocław Poljska	LZP01- 06052/15/R29NP	PN-EN 1366-4 +A1:2011

3.2. Rezultati ispitivanja

Rezultati ispitivanja						
Broj brtve linearnog spoja u skladu s odgovarajućim ispitnim izvješćem	Tip brtve linearnog spoja u skladu s točkom 2.2 / širina brtve linearnog spoja	Orijentacija brtve linearnog spoja u skladu s EN 13501-2	E - integritet			I – toplinska izolacija
			Pukotine ili rastvori veći od danih dimenzija	Zapaljenje blazinice	Pukotine ili rastvori veći od danih dimenzija	Maksimalno povećanje temperature u bilo kojoj točki, ograničeno na 180 K iznad početne prosječne temperature
			Kriterij nije postignut u dano vrijeme, [min]			
Ispitno izvješće br. LZP01-06052/15/R29NP						
Brtve linearnih spojeva izrađene pomoću PREMIUM B1 STRAW pjene, pri debljini zida od 150 mm izrađenog od blokova porastog betona gustoće 600 kg/m³						
1	Tip 2 / 30 mm	T	240	39	240	240
2	Tip 2 / 20 mm	T	240	70	240	78
3	Tip 2 / 10 mm	T	240	173	240	183
19	Tip 1 / 30 mm	V	240	71	240	240
20	Tip 1 / 20 mm	V	240	128	240	118
21	Tip 1 / 10 mm	V	240	240	240	223
Brtve linearnih spojeva izrađene pomoću PREMIUM B1 GUN pjene, pri debljini zida od 150 mm izrađenog od blokova porastog betona gustoće 600 kg/m³						
7	Tip 2 / 30 mm	T	240	44	240	51
8	Tip 2 / 20 mm	T	240	94	240	95
9	Tip 2 / 10 mm	T	240	181	240	195
22	Tip 1 / 30 mm	V	240	63	240	61
23	Tip 1 / 20 mm	V	240	103	240	100
24	Tip 1 / 10 mm	V	240	108	240	240

Rezultati ispitivanja						
Broj brtve linearnog spoja u skladu s odgovarajućim ispitnim izvješćem	Tip brtve linearnog spoja u skladu s točkom 2.2 / širina brtve linearnog spoja	Orijentacija brtve linearnog spoja u skladu s EN 13501-2	E - integritet			I – toplinska izolacija
			Pukotine ili rastvori veći od danih dimenzija	Zapaljenje blazinice	Pukotine ili rastvori veći od danih dimenzija	Maksimalno povećanje temperature u bilo kojoj točki, ograničeno na 180 K iznad početne prosječne temperature
			Kriterij nije postignut u dano vrijeme, [min]			
Ispitno izvješće br. LZP01-00867/17/Z00NZP						
Brtve linearnih spojeva izrađene pomoću PREMIUM B1 STRAW pjene, pri debljini zida od 200 mm izrađenog od blokova porastog betona gustoće 600 kg/m ³						
1	Tip 2 / 30 mm	T	240	77	240	240
3	Tip 2 / 10 mm	T	240	198	240	195
12	Tip 1 / 30 mm	V	240	99	240	220
10	Tip 1 / 20 mm	V	240	163	240	240
19	Tip 1 / 10 mm	V	240	211	240	215
Brtve linearnih spojeva izrađene pomoću PREMIUM B1 GUN pjene, pri debljini zida od 200 mm izrađenog od blokova porastog betona gustoće 600 kg/m ³						
2	Tip 2 / 30 mm	T	240	240	87	103
4	Tip 2 / 10 mm	T	240	240	97	94
13	Tip 1 / 30 mm	V	240	240	92	240
9	Tip 1 / 20 mm	V	240	142	240	225
11	Tip 1 / 10 mm	V	240	240	240	240
Brtve linearnih spojeva izrađene pomoću PREMIUM B1 STRAW pjene, pri debljini zida od 240 mm izrađenog od blokova porastog betona gustoće 600 kg/m ³						
5	Tip 2 / 30 mm	T	240	103	240	102
7	Tip 2 / 10 mm	T	240	240	240	240
15	Tip 1 / 30 mm	V	240	115	240	240
17	Tip 1 / 20 mm	V	240	240	240	240
20	Tip 1 / 10 mm	V	240	240	240	240
Brtve linearnih spojeva izrađene pomoću PREMIUM B1 GUN pjene, pri debljini zida od 240 mm izrađenog od blokova porastog betona od 600 kg/m ³						
6	Tip 2 / 30 mm	T	240	240	126	240
8	Tip 2 / 10 mm	T	240	213	240	240
14	Tip 1 / 30 mm	V	240	112	240	115
18	Tip 1 / 20 mm	V	240	239	240	240
16	Tip 1 / 10 mm	V	240	240	240	240

4. KLASIFIKACIJA I PODRUČJE PRIMJENE

3.1. Referenca klasifikacije

Ova klasifikacija provedena je u skladnosti s Odredbom 7. norme EN 13501-2:2016.

4.2. Klasifikacija

Brtve linearnih spojeva u zidu klasificirane su u skladu sa sljedećim kombinacijama parametara radnih svojstava i razreda, kako je primjereno:

R	E	I	W		t	t	-	M	S	C	IncSlow	sn	ef	r
---	---	---	---	--	---	---	---	---	---	---	---------	----	----	---

4.2.1. Razred vatrootpornosti brtve linearnog spoja **Tipa 1** izrađene pomoću **PREMIUM B1 STRAW** pjene za nanošenje slamčicom, pri debljini zida od **min. 150 mm**, u skladu s točkom 2.2.1

Razred vatrootpornosti: EI 180 – V – X – F – W 10 *)

Razred vatrootpornosti: EI 90 – V – X – F – W 11 do 20 *)

Razred vatrootpornosti: EI 60 – V – X – F – W 21 do 30 *)

4.2.2. Razred vatrootpornosti brtve linearnog spoja **Tipa 1** izrađene pomoću **PREMIUM B1 STRAW** pjene za nanošenje slamčicom, pri debljini zida od **min. 200 mm**, u skladu s točkom 2.2.1

Razred vatrootpornosti: EI 180 – V – X – F – W 10 *)

Razred vatrootpornosti: EI 120 – V – X – F – W 11 do 20 *)

Razred vatrootpornosti: EI 90 – V – X – F – W 21 do 30 *)

4.2.3. Razred vatrootpornosti brtve linearnog spoja **Tipa 1** izrađene pomoću **PREMIUM B1 STRAW** pjene za nanošenje slamčicom, pri debljini zida od **min. 240 mm**, u skladu s točkom 2.2.1

Razred vatrootpornosti: EI 240 – V – X – F – W 10 *)

Razred vatrootpornosti: EI 240 – V – X – F – W 11 do 20 *)

Razred vatrootpornosti: EI 90 – V – X – F – W 21 do 30 *)

4.2.4. Razred vatrootpornosti brtve linearnog spoja **Tipa 1** izrađene pomoću **PREMIUM B1 STRAW** pjene za nanošenje slamčicom, pri debljini zida od **min. 150 mm**, u skladu s točkom 2.2.2

Razred vatrootpornosti: EI 180 – T – X – F – W 10 *)

Razred vatrootpornosti: EI 60 – T – X – F – W 11 do 20 *)

Razred vatrootpornosti: EI 60 – T – X – F – W 21 do 30 *)

4.2.5. Razred vatrootpornosti brtve linearnog spoja **Tipa 2** izrađene pomoću **PREMIUM B1 STRAW** pjene za nanošenje slamčicom, pri debljini zida od **min. 200 mm**, u skladu s točkom 2.2.2

Razred vatrootpornosti: EI 180 – T – X – F – W 10 *)

Razred vatrootpornosti: EI 60 – T – X – F – W 11 do 20 *)

Razred vatrootpornosti: EI 60 – T – X – F – W 21 do 30 *)

4.2.6. Razred vatrootpornosti brtve linearnog spoja **Tipa 2** izrađene pomoću **PREMIUM B1 STRAW** pjene za nanošenje slamčicom, pri debljini zida od **min. 240 mm**, u skladu s točkom 2.2.2.

Razred vatrootpornosti: EI 240 – T – X – F – W 10 *)

Razred vatrootpornosti: EI 90 – T – X – F – W 11 do 20 *)
--

Razred vatrootpornosti: EI 90 – T – X – F – W 21 do 30 *)
--

4.2.7. Razred vatrootpornosti brtve linearnog spoja **Tipa 1** izrađene pomoću **PREMIUM B1 GUN** pjene za nanošenje pištoljem, pri debljini zida od **min. 150 mm**, u skladu s točkom 2.2.1

Razred vatrootpornosti: EI 90 – V – X – F – W 10 *)
--

Razred vatrootpornosti: EI 90 – V – X – F – W 11 do 20 *)
--

Razred vatrootpornosti: EI 60 – V – X – F – W 21 do 30 *)
--

4.2.8. Razred vatrootpornosti brtve linearnog spoja **Tipa 1** izrađene pomoću **PREMIUM B1 GUN** pjene za nanošenje pištoljem, pri debljini zida od **min. 200 mm**, u skladu s točkom 2.2.1

Razred vatrootpornosti: EI 240 – V – X – F – W 10 *)

Razred vatrootpornosti: EI 120 – V – X – F – W 11 do 20 *)

Razred vatrootpornosti: EI 90 – V – X – F – W 21 do 30 *)
--

4.2.9. Razred vatrootpornosti brtve linearnog spoja **Tipa 1** izrađene pomoću **PREMIUM B1 GUN** pjene za nanošenje pištoljem, pri debljini zida od **min. 240 mm**, u skladu s točkom 2.2.1.

Razred vatrootpornosti: EI 240 – V – X – F – W 10 *)

Razred vatrootpornosti: EI 180 – V – X – F – W 11 do 20 *)

Razred vatrootpornosti: EI 90 – V – X – F – W 21 do 30 *)

4.2.10. Razred vatrootpornosti brtve linearnog spoja **Tipa 2** izrađene pomoću **PREMIUM B1 GUN** pjene za nanošenje pištoljem, pri debljini zida od **min. 150 mm**, u skladu s točkom 2.2.2

Razred vatrootpornosti: EI 180 – T – X – F – W 10 *)

Razred vatrootpornosti: EI 90 – T – X – F – W 11 do 20 *)

Razred vatrootpornosti: EI 30 – T – X – F – W 21 do 30 *)

4.2.11. Razred vatrootpornosti brtve linearnog spoja **Tipa 2** izrađene pomoću **PREMIUM B1 GUN** pjene za nanošenje pištoljem, pri debljini zida od **min. 200 mm**, u skladu s točkom 2.2.2

Razred vatrootpornosti: EI 180 – T – X – F – W 10 *)

Razred vatrootpornosti: EI 90 – T – X – F – W 11 do 20 *)

Razred vatrootpornosti: EI 60 – T – X – F – W 21 do 30 *)

4.2.12. Razred vatrootpornosti brtve linearnog spoja **Tipa 2** izrađene pomoću **PREMIUM B1 GUN** pjene za nanošenje pištoljem, pri debljini zida od **min. 240 mm**, u skladu s točkom 2.2.2

Razred vatrootpornosti: EI 180 – T – X – F – W 10 *)

Razred vatrootpornosti: EI 120 – T – X – F – W 11 do 20 *)

Razred vatrootpornosti: EI 120 – T – X – F – W 21 do 30 *)

***) Ključ**

E – integritet;

I – toplinska izolacija;

V – orijentacija: vertikalna potporna konstrukcija – vertikalni spoj

T – orijentacija: vertikalna potporna konstrukcija – horizontalni spoj;

X – bez pomaka;

F – brtva učinjena na gradilištu;

W – raspon širine spoja (u mm).

4.3. Područje primjene

Ova klasifikacija vrijedi za sljedeće krajnje primjene u skladu s normom EN 1366-4:2006+A1:2010:

4.3.1. Moguća orijentacija brtvi linearnih spojeva u skladu s PN-EN 1366-4+A1:2011:

- **B** – vertikalni linearni spoj u vertikalnoj potpornoj konstrukciji – linearni spojevi klasificirani u točki 4.2.1. – 4.2.3. i 4.2.7. – 4.2.9.;


- **C** – horizontalni linearni spoj u vertikalnoj potpornoj konstrukciji – linearni spojevi klasificirani u točki 4.2.4. – 4.2.6. i 4.2.10. – 4.2.12.;

4.3.2. Klasifikacija navedena u točkama 4.2.1., 4.2.4., 4.2.7. i 4.2.10. vrijedi za brtve linearnih spojeva u elementima za odvajanje od porastog betona, betona, betonskih blokova ili zidanih zidova debljine 150 mm i gustoće min 600 kg/m³.

4.3.3. Klasifikacija navedena u točkama 4.2.2., 4.2.5., 4.2.8. i 4.2.11. vrijedi za brtve linearnih spojeva u elementima za odvajanje od porastog betona, betona, betonskih blokova ili zidanih zidova debljine 200 mm i gustoće min 600 kg/m³.

4.3.4. Klasifikacija navedena u točkama 4.2.3., 4.2.6., 4.2.9. i 4.2.12. vrijedi za brtve linearnih spojeva u elementima za odvajanje od porastog betona, betona, betonskih blokova ili zidanih zidova debljine 240 mm i gustoće min 600 kg/m³.

4.3.5. Moguća pozicija brtvi linearnih spojeva u potpornoj konstrukciji naznačena je na slici 1. i 2. Klasifikacija navedena u točki 4.2. primjenjiva je samo na površine elemenata za brtvljene s ravnim paralelnim rubom, u skladu sa slikom 3.



Slika 3.: Rubovi elemenata za brtvljenje

5 OGRANIČENJA

Ova klasifikacija ostaje valjana sve dok:

- se ne mijenjaju ispitne metode,
- se ne mijenja proizvodni standard ili tehničko odobrenje,
- izmjene u konstrukciji ili materijalima ne premašuju granice područja primjene navedene u 4.3.

Ovo izvješće o klasifikaciji izdano je u 3 primjerka. Dodatne potpisane kopije može izdati Odjel za istraživanje požara (*Fire Research Department*) ITB-a samo na zahtjev vlasnika izvješća.

Ovaj dokument o klasifikaciji ne predstavlja odobrenje tipa ili certifikaciju proizvoda.

U slučaju nejasnoća, osnova za tumačenje ovog izvješća je poljska jezična verzija.

POTPISANO

/potpis nečitalak/

Krzysztof Lenarcik

magistar inženjer građevinarstva

/potpis nečitalak/

Bartłomiej Sędlak,

magistar inženjer građevinarstva

ODOBRENO

/potpis nečitalak/

Marek Łukomski,

magistar inženjer građevinarstva

Ja, WIDIAN ZEITOUN, stalni sudski tumač za engleski, francuski i češki jezik, imenovana rješenjem predsjednika Županijskog suda u Zagrebu broj 4 Su-1371/18 od 15.4.2019. potvrđujem da gornji prijevod potpuno odgovara izvorniku sastavljenom na engleskom jeziku.

Zagreb, 18. ožujka 2020.

Br. 167/2020





Instytut Techniki Budowlanej

Research and development works | Accredited Group of Laboratories |

Notified Body N° 1488 | EOTA member | Certified management systems ISO 9001, ISO 27001

CLASSIFICATION OF FIRE RESISTANCE

IN ACCORDANCE WITH EN 13501-2:2016

Sponsor:

SELENA FM S.A.
2-4, Strzegomska St.
53-611 Wrocław
Poland

Prepared by:

Fire Research Department
Building Research Institute
1, Filtrowa St.
PL 00-611 Warsaw

Product name:

Linear joint seals made using PREMIUM B1
STRAW foam or PREMIUM B1 GUN foam
of Orion PU Sp. z o.o. company

Classification report No.:

06052/15/R29NP/ENG

Issue number:

1

Copy No. 1

Date of issue:

2017.12.13

**This classification report consists of 11 pages and only to be used
or reproduced in its entirety.**

1 INTRODUCTION

The classification report defines the resistance to fire classification assigned to the element – linear joint seals in wall, made using PREMIUM B1 STRAW foam or PREMIUM B1 GUN foam of Orion PU Sp. z o.o. company, in accordance with the procedures given in EN 13501-2:2016.

2 DETAILS OF CLASSIFIED PRODUCT

2.1 General

Element – linear joint seals in wall, made using PREMIUM B1 STRAW foam or PREMIUM B1 GUN foam of Orion PU Sp. z o.o. company.

2.2 Description

Element – linear joint seals made using PREMIUM B1 STRAW foam or PREMIUM B1 GUN foam are described below.

Linear joint seals are made using:

- a) fireproof polyurethane foam PREMIUM B1 STRAW – straw version – application of the polyurethane foam by elastic straw, or
- b) fireproof polyurethane foam PREMIUM B1 GUN – gun version – application of the polyurethane foam by gun.

Views and cross-sections of the linear joint seals are presented in fig. 1 and 2.

2.2.1. Type 1 – vertical linear joint seals in vertical supporting construction




Fig. 1 View and cross-section of the vertical linear joint seal in wall

2.2.2. Type 2 – horizontal linear joint seals in vertical supporting construction




Fig. 2 View and cross-section of the horizontal linear joint seal in wall

3 TEST REPORTS/EXTENDED APPLICATION REPORTS AND TEST RESULTS IN SUPPORT OF THE CLASSIFICATION

3.1 Test report/extended application reports

Name of laboratory	Name of sponsor	Report ref. No	Test standard
Fire Testing Laboratory Building Research Institute 2, Przemysłowa St. 26-670 Pionki	SELENA FM S.A. 2-4, Strzegomska St. 53-611 Wrocław Poland	LZP01- 00867/17/Z00NZP	PN-EN 1366-4 +A1:2011
Fire Testing Laboratory Building Research Institute 2, Przemysłowa St. 26-670 Pionki	SELENA FM S.A. 2-4, Strzegomska St. 53-611 Wrocław Poland	LZP01- 06052/15/R29NP	PN-EN 1366-4 +A1:2011

3.2 Test results

Test results						
Linear joint seal numbering in accordance with the appropriate test report	Linear joint seal type in accordance with p. 2.2 / width of the linear joint seal	Linear joint seal orientation in accordance with EN 13501-2	E - integrity			I – thermal insulation
			Cracks or openings in excess of given dimensions	Ignition of a cotton pad	Cracks or openings in excess of given dimensions	Maximum temperature rise at any point, limited to 180 K above the initial mean temperature
			Criterion not achieved to the time, [min]			
Test Report No. LZP01-06052/15/R29NP						
Linear joint seals made using PREMIUM B1 STRAW foam, in wall thickness of 150 mm made of aerated concrete blocks density of 600 kg/m ³						
1	Type 2 / 30 mm	T	240	39	240	240
2	Type 2 / 20 mm	T	240	70	240	78
3	Type 2 / 10 mm	T	240	173	240	183
19	Type 1 / 30 mm	V	240	71	240	240
20	Type 1 / 20 mm	V	240	128	240	118
21	Type 1 / 10 mm	V	240	240	240	223
Linear joint seals made using PREMIUM B1 GUN foam, in wall thickness of 150 mm made of aerated concrete blocks density of 600 kg/m ³						
7	Type 2 / 30 mm	T	240	44	240	51
8	Type 2 / 20 mm	T	240	94	240	95
9	Type 2 / 10 mm	T	240	181	240	195
22	Type 1 / 30 mm	V	240	63	240	61
23	Type 1 / 20 mm	V	240	103	240	100
24	Type 1 / 10 mm	V	240	108	240	240

Test results						
Linear joint seal numbering in accordance with the appropriate test report	Linear joint seal type in accordance with p. 2.2 / width of the linear joint seal	Linear joint seal orientation in accordance with EN 13501-2	E - integrity			I – thermal insulation
			Cracks or openings in excess of given dimensions	Ignition of a cotton pad	Cracks or openings in excess of given dimensions	Maximum temperature rise at any point, limited to 180 K above the initial mean temperature
			Criterion not achieved to the time, [min]			
Test Report No. LZP01-00867/17/Z00NZP						
Linear joint seals made using PREMIUM B1 STRAW foam, in wall thickness of 200 mm made of aerated concrete blocks density of 600 kg/m ³						
1	Type 2 / 30 mm	T	240	77	240	240
3	Type 2 / 10 mm	T	240	198	240	195
12	Type 1 / 30 mm	V	240	99	240	220
10	Type 1 / 20 mm	V	240	163	240	240
19	Type 1 / 10 mm	V	240	211	240	215
Linear joint seals made using PREMIUM B1 GUN foam, in wall thickness of 200 mm made of aerated concrete blocks density of 600 kg/m ³						
2	Type 2 / 30 mm	T	240	240	87	103
4	Type 2 / 10 mm	T	240	240	97	94
13	Type 1 / 30 mm	V	240	240	92	240
9	Type 1 / 20 mm	V	240	142	240	225
11	Type 1 / 10 mm	V	240	240	240	240
Linear joint seals made using PREMIUM B1 STRAW foam, in wall thickness of 240 mm made of aerated concrete blocks density of 600 kg/m ³						
5	Type 2 / 30 mm	T	240	103	240	102
7	Type 2 / 10 mm	T	240	240	240	240
15	Type 1 / 30 mm	V	240	115	240	240
17	Type 1 / 20 mm	V	240	240	240	240
20	Type 1 / 10 mm	V	240	240	240	240
Linear joint seals made using PREMIUM B1 GUN foam, in wall thickness of 240 mm made of aerated concrete blocks density of 600 kg/m ³						
6	Type 2 / 30 mm	T	240	240	126	240
8	Type 2 / 10 mm	T	240	213	240	240
14	Type 1 / 30 mm	V	240	112	240	115
18	Type 1 / 20 mm	V	240	239	240	240
16	Type 1 / 10 mm	V	240	240	240	240

4 CLASSIFICATION AND FIELD OF APPLICATION

4.1 Reference of classification

This classification has been carried out in accordance with Clause 7 of EN 13501-2:2016.

4.2 Classification

The linear joint seals in wall are classified according to the following combinations of performance parameters and classes as appropriate:

R	E	I	W		t	t	-	M	S	C	IncSlow	sn	ef	r
---	---	---	---	--	---	---	---	---	---	---	---------	----	----	---

- 4.2.1** Fire resistance class of linear joint seal **Type 1** made using **PREMIUM B1 STRAW** foam, in wall thickness of **min. 150 mm**, in accordance with p. 2.2.1

Fire resistance class: EI 180 – V – X – F – W 10 *)

Fire resistance class: EI 90 – V – X – F – W 11 to 20 *)

Fire resistance class: EI 60 – V – X – F – W 21 to 30 *)

- 4.2.2** Fire resistance class of linear joint seal **Type 1** made using **PREMIUM B1 STRAW** foam, in wall thickness of **min. 200 mm**, in accordance with p. 2.2.1

Fire resistance class: EI 180 – V – X – F – W 10 *)

Fire resistance class: EI 120 – V – X – F – W 11 to 20 *)

Fire resistance class: EI 90 – V – X – F – W 21 to 30 *)

- 4.2.3** Fire resistance class of linear joint seal **Type 1** made using **PREMIUM B1 STRAW** foam, in wall thickness of **min. 240 mm**, in accordance with p. 2.2.1

Fire resistance class: EI 240 – V – X – F – W 10 *)

Fire resistance class: EI 240 – V – X – F – W 11 to 20 *)

Fire resistance class: EI 90 – V – X – F – W 21 to 30 *)

- 4.2.4** Fire resistance class of linear joint seal **Type 2** made using **PREMIUM B1 STRAW** foam, in wall thickness of **min. 150 mm**, in accordance with p. 2.2.2

Fire resistance class: EI 120 – T – X – F – W 10 *)

Fire resistance class: EI 60 – T – X – F – W 11 to 20 *)

Fire resistance class: EI 30 – T – X – F – W 21 to 30 *)

- 4.2.5** Fire resistance class of linear joint seal **Type 2** made using **PREMIUM B1 STRAW** foam, in wall thickness of **min. 200 mm**, in accordance with p. 2.2.2

Fire resistance class: EI 180 – T – X – F – W 10 *)

Fire resistance class: EI 60 – T – X – F – W 11 to 20 *)

Fire resistance class: EI 60 – T – X – F – W 21 to 30 *)

- 4.2.6** Fire resistance class of linear joint seal **Type 2** made using **PREMIUM B1 STRAW** foam, in wall thickness of **min. 240 mm**, in accordance with p. 2.2.2

Fire resistance class: EI 240 – T – X – F – W 10 *)

Fire resistance class: EI 90 – T – X – F – W 11 to 20 *)

Fire resistance class: EI 90 – T – X – F – W 21 to 30 *)

- 4.2.7** Fire resistance class of linear joint seal **Type 1** made using **PREMIUM B1 GUN** foam, in wall thickness of **min. 150 mm**, in accordance with p. 2.2.1

Fire resistance class: EI 90 – V – X – F – W 10 *)

Fire resistance class: EI 90 – V – X – F – W 11 to 20 *)

Fire resistance class: EI 60 – V – X – F – W 21 to 30 *)

- 4.2.8** Fire resistance class of linear joint seal **Type 1** made using **PREMIUM B1 GUN** foam, in wall thickness of **min. 200 mm**, in accordance with p. 2.2.1

Fire resistance class: EI 240 – V – X – F – W 10 *)

Fire resistance class: EI 120 – V – X – F – W 11 to 20 *)

Fire resistance class: EI 90 – V – X – F – W 21 to 30 *)

- 4.2.9** Fire resistance class of linear joint seal **Type 1** made using **PREMIUM B1 GUN** foam, in wall thickness of **min. 240 mm**, in accordance with p. 2.2.1

Fire resistance class: EI 240 – V – X – F – W 10 *)

Fire resistance class: EI 180 – V – X – F – W 11 to 20 *)

Fire resistance class: EI 90 – V – X – F – W 21 to 30 *)

- 4.2.10** Fire resistance class of linear joint seal **Type 2** made using **PREMIUM B1 GUN** foam, in wall thickness of **min. 150 mm**, in accordance with p. 2.2.2

Fire resistance class: EI 180 – T – X – F – W 10 *)

Fire resistance class: EI 90 – T – X – F – W 11 to 20 *)

Fire resistance class: EI 30 – T – X – F – W 21 to 30 *)

- 4.2.11** Fire resistance class of linear joint seal **Type 2** made using **PREMIUM B1 GUN** foam, in wall thickness of **min. 200 mm**, in accordance with p. 2.2.2

Fire resistance class: EI 180 – T – X – F – W 10 *)

Fire resistance class: EI 90 – T – X – F – W 11 to 20 *)

Fire resistance class: EI 60 – T – X – F – W 21 to 30 *)

- 4.2.12** Fire resistance class of linear joint seal **Type 2** made using **PREMIUM B1 GUN** foam, in wall thickness of **min. 240 mm**, in accordance with p. 2.2.2

Fire resistance class: EI 180 – T – X – F – W 10 *)

Fire resistance class: EI 120 – T – X – F – W 11 to 20 *)

Fire resistance class: EI 120 – T – X – F – W 21 to 30 *)

***) Key**

- E** – integrity;
- I** – thermal insulation;
- V** – orientation: vertical supporting construction – vertical joint;
- T** – orientation: vertical supporting construction – horizontal joint;
- X** – without movement;
- F** – sealing made on construction site;
- W** – joint widths range (in mm).

4.3 Field of application

This classification is valid for the following end use applications in accordance with EN 1366-4:2006 +A1:2010:

- 4.3.1** The possible orientation of the linear joint seals in accordance with PN-EN 1366-4+A1:2011:

- B – vertical linear joint in vertical supporting construction – linear joints classified in p. 4.2.1 – 4.2.3 and 4.2.7 – 4.2.9;
- C – horizontal linear joint in vertical supporting construction – linear joints classified in p. 4.2.4 – 4.2.6 and 4.2.10 – 4.2.12.

- 4.3.2** Classification given in p. 4.2.1, 4.2.4, 4.2.7 i 4.2.10 is valid for linear joint seals in aerated concrete, concrete, block work and masonry wall separating elements thickness of min. 150 mm and density of min. 600 kg/m³.

- 4.3.3** Classification given in p. 4.2.2, 4.2.5, 4.2.8 i 4.2.11 is valid for linear joint seals in aerated concrete, concrete, block work and masonry wall separating elements thickness of min. 200 mm and density of min. 600 kg/m³.

- 4.3.4** Classification given in p. 4.2.3, 4.2.6, 4.2.9 i 4.2.12 is valid for linear joint seals in aerated concrete, concrete, block work and masonry wall separating elements thickness of min. 240 mm and density of min. 600 kg/m³.
- 4.3.5** The possible position of linear joint seals in supporting construction is presented in fig. 1 and 2. Classification given in p. 4.2 is applicable only to straight parallel edge surfaces of sealing elements, in accordance with fig. 3.




Fig. 3 Edge surfaces of sealing elements

5 LIMITATIONS

This classification given remains valid as long as:

- test method remains unchanged,
- product standard or technical approval remains unchanged,
- constructional or material modifications do not exceed limits of the field of application defined in 4.3.

This classification report has been issued in 3 copies. Additional signed copies can be issued by Fire Research Department of ITB on the request of the report's owner only.

This classification document does not represent type approval or certification of the product.

In the case of ambiguity, the base of interpretation of this report is its version in Polish.

SIGNED


Krzysztof Lenarcik, M. Sc. Civil Eng.


Bartłomiej Sędkak, M. Sc. Civil Eng.

APPROVED


Marek Łukomski, M. Sc. Civil Eng.